Ultrasonic sensor		UB120-12GM-E5-V1
Oltrasoffic sensor		0B120-12GM-E3-V1
	ĺ	
	Technical data	
	General specifications	45 400
E	Sensing range Adjustment range	15 120 mm 20 120 mm
	Dead band	0 15 mm
	Standard target plate	10 mm x 10 mm
	Transducer frequency	approx. 850 kHz
	Response delay Indicators/operating means	approx. 9 ms
	LED yellow	indication of the switching state
		flashing: program function object detected
	LED red	solid red: Error red, flashing: program function, object not detected
	Electrical specifications	rea, hashing. program landion, object for detected
	Operating voltage UB	10 30 V DC , ripple 10 % _{SS}
	No-load supply current I ₀	≤ 30 mA
	Input Input type	1 program input
	inputtype	operating distance 1: $-U_B \dots + 1 V$, operating distance 2: $+6 V \dots + U_B$
	Output	input impedance: > 4,7 k Ω program pulse: ≥ 1 s
Model Number	Output type	1 switch output PNP Normally open/closed , programmable
Model Number	Rated operating current Ie	100 mA, short-circuit/overload protected
UB120-12GM-E5-V1	Default setting	Switch point A1: 20 mm Switch point A2: 120 mm \leq 3 V
Single head system	Voltage drop U _d Repeat accuracy	$\leq 3 \vee$
Single head system	Switching frequency f	≤ 52 Hz
Features	Range hysteresis H	1 % of the set operating distance
Extremely narrow projection cone	Temperature influence Ambient conditions	± 1.5 % of full-scale value
	Ambient temperature	-25 70 °C (-13 158 °F)
Switch output	Storage temperature	-40 85 °C (-40 185 °F)
 Very small unusable area 	Mechanical specifications	Connector M10 x 1 4 pin
• 5 different output functions can be	Connection type Degree of protection	Connector M12 x 1 , 4-pin IP67
set	Material	
Short response time	Housing	brass, nickel-plated
	Transducer	epoxy resin/hollow glass sphere mixture; foam polyurethane, cover PBT
Diagrams	Mass	25 g
	Compliance with standards and directives	
Characteristic response curve	Standard conformity	
Distance Y [mm]	Standards	EN 60947-5-2:2007 + A1:2012 IEC 60947-5-2:2007 + A1:2012
	Approvals and certificates	
50	UL approval	cULus Listed, General Purpose
	CSA approval	cCSAus Listed, General Purpose
25	CCC approval	CCC approval / marking not required for products rated \leq 36 V
0 2 1		
-25		
-50		
-75		
0 25 50 75 100 125 150 175 200 Distance X [mm]		
∱Υ Γ		
Curve 1: flat surface 10 mm x 10 mm Curve 2: round bar, Ø 8 mm		

Refer to "General Notes Relating to Pepperl+Fuchs Product Information".

Pepperl+Fuchs Group www.pepperl-fuchs.com


Release date: 2016-04-25 09:32 Date of issue: 2016-04-25 188174_eng.xml

USA: +1 330 486 0001 fa-info@us.pepperl-fuchs.com


Singapore: +65 6779 9091 fa-info@sg.pepperl-fuchs.com



Dimensions



Electrical Connection



Core colours in accordance with EN 60947-5-2.

Pinout




Wire colors in accordance with EN 60947-5-2

1	BN	(brown)
2	WH	(white)
3	BU	(blue)
4	BK	(black)

Additional Information

Programmable output modes



5. A1 -> ∞, A2 -> ∞: Object presence detection mode Object detected: Switch output closed No object detected: Switch output open

 Perfer to "General Notes Relating to Pepperl+Fuchs Product Information".

 Pepperl+Fuchs Group
 USA: +1 330 486 0001
 G

 www.pepperl-fuchs.com
 fa-info@us.pepperl-fuchs.com
 fa-info@us.pepperl-fuchs.com

Germany: +49 621 776 4411 fa-info@de.pepperl-fuchs.com

Accessories

UB-PROG2 Programming unit

BF 5-30

Universal mounting bracket for cylindrical sensors with a diameter of 5 ... 30 mm

BF 12 Mounting flange, 12 mm

BF 12-F Mounting flange with dead stop, 12 mm

V1-G-2M-PVC Female cordset, M12, 4-pin, PVC cable

V1-W-2M-PUR Female cordset, M12, 4-pin, PUR cable

UVW90-M12 Ultrasonic -deflector

Adjusting the switching points

The ultrasonic sensor features a switch output with two teachable switching points. These are set by applying the supply voltage $-U_B$ or $+U_B$ to the TEACH-IN input. The supply voltage must be applied to the TEACH-IN input for at least 1 s. LEDs indicate whether the sensor has recognised the target during the TEACH-IN procedure. Switching point A1 is taught with $-U_B$, A2 with $+U_B$.

Five different output functions can be set

- 1. Window mode, normally-open function
- 2. Window mode, normally-closed function
- 3. one switching point, normally-open function
- 4. one switching point, normally-closed function
- 5. Detection of object presence

TEACH-IN window mode, normally-open function

- Set target to near switching point
- TEACH-IN switching point A1 with -U_B
- Set target to far switching point
- TEACH-IN switching point A2 with +U_B

TEACH-IN window mode, normally-closed function

- Set target to near switching point
- TEACH-IN switching point A2 with $+ \ensuremath{\text{U}_{\text{B}}}$
- Set target to far switching point
- TEACH-IN switching point A1 with -UB

TEACH-IN switching point, normally-open function

- Set target to near switching point
- TEACH-IN switching point A2 with +U_B
- Cover sensor with hand or remove all objects from sensing range
- TEACH-IN switching point A1 with -U_B

TEACH-IN switching point, normally-closed function

- Set target to near switching point
- TEACH-IN switching point A1 with -U_B
- Cover sensor with hand or remove all objects from sensing range
- TEACH-IN switching point A2 with $+ U_{\text{B}}$

TEACH-IN detection of objects presence

- Cover sensor with hand or remove all objects from sensing range
- TEACH-IN switching point A1 with -UB
- TEACH-IN switching point A2 with +UB

LED Displays

Displays in dependence on operating mode	Red LED	Yellow LED
TEACH-IN switching point:		
Object detected	off	flashes
No object detected	flashes	off
Object uncertain (TEACH-IN invalid)	On	off
Normal operation	off	Switching state
Fault	on	Previous state

Installation conditions

If the sensor is installed at places, where the environment temperature can fall below 0 °C, for the sensors fixation, one of the mounting flanges BF 12, BF 12-F or BF 5-30 must be used. In case of direct mounting of the sensor in a through hole, it has to be fixed at the middle of the housing thread.

Refer to "General Notes Relating to Pepperl+Fuchs Product Information"

Pepperl+Fuchs Group www.pepperl-fuchs.com



Release date: 2016-04-25 09:32 Date of issue: 2016-04-25 188174_eng.xml

 Refer to "General Notes Relating to Pepperl+Fuchs Product Information".

 Pepperl+Fuchs Group
 USA: +1 330 486 0001
 G

 www.pepperl-fuchs.com
 fa-info@us.pepperl-fuchs.com
 fa-info@us.pepperl-fuchs.com

Germany: +49 621 776 4411 fa-info@de.pepperl-fuchs.com

Singapore: +65 6779 9091 fa-info@sg.pepperl-fuchs.com



4